



NOTES:

1. MAINTAIN UNIFORM TRENCH WIDTH TO 12" OVER PIPE.
2. SEE PAVEMENT DETAILS FOR PAVING AND PATCHING REQUIREMENTS. OPEN TRENCHES MUST BE PAVED AT THE END OF EACH WEEK.
3. MAINTAIN MINIMUM OF 4.0' OF COVER OVER PIPE.
4. IF EXCAVATION BELOW NORMAL GRADE IS REQUIRED, PROVIDE SHEETING 2.0' BELOW TRENCH BOTTOM. BACKFILL TRENCH FROM TRENCH BOTTOM TO NORMAL GRADE WITH COMPACTED GRAVEL (6" COMPACTED LIFTS)
5. 2" RIGID INSULATION WILL BE REQUIRED IN AREAS WHERE LESS THAN 4.0' OF COVER OVER TOP OF PIPE OR WHERE REQUIRED BY ENGINEER.



**DEPARTMENT OF PUBLIC WORKS
ENGINEERING DIVISION
TOWN OF BILLERICA,
MASSACHUSETTS**

**WATER / SEWER / DRAIN
PIPE TRENCH**

CREATED BY: DCW/KCS

SCALE: NTS

FILE:

CHECKED BY: GA/JT

DATE: 06/29/2015