



**NOTES:**

1. ALL JOINTS SHALL BE COMPRESSION TYPE.
2. COPPER TUBING SHALL BE BACKFILLED WITH 3/4" CRUSHED STONE BY HAND TO 6" ABOVE COPPER TUBING.
3. ANY CORPORATION STOP LARGER THAN 1" SHALL HAVE A SADDLE.



**DEPARTMENT OF PUBLIC WORKS  
ENGINEERING DIVISION  
TOWN OF BILLERICA,  
MASSACHUSETTS**

**WATER SERVICE  
CONNECTION**

CREATED BY: DCW/KCS

SCALE: NTS

FILE:

CHECKED BY: GA/JT

DATE: 06/29/2015